



ASSA ABLOY

ASSA ABLOY, the global leader
in door opening solutions.

INSTALLATION INSTRUCTIONS

Positive Pressure (UL 10C) Labeled Door

THIS DOOR HAS BEEN LABELED FOR COMPLIANCE WITH UL 10C. IT DOES NOT REQUIRE THE APPLICATION OF AN ADDITIONAL INTUMESCENT EDGE-SEALING SYSTEM. TO MAINTAIN THE VALIDITY OF THIS CERTIFICATION, THE DOOR INSTALLER MUST FOLLOW THESE INSTRUCTIONS. THEY SHOULD BE KEPT ON FILE ON THE BUILDING PREMISES FOR VERIFICATION BY THE AUTHORITY HAVING JURISDICTION.

1. Verify that frame is compatible with door and properly installed. See item #4 if a smoke rating is required.
2. Install hardware per hardware manufacturer's instructions.
3. Install lite kit (if required) per lite kit manufacturer's instructions. The lite kit must be listed in accordance with UL10C.
4. When a smoke rating (S Label) is required, a fire-rated smoke and draft control gasket shall be installed in the opening. This gasket is to be labeled showing compliance with UL10C. Install gaskets per manufacturer's instructions. Gasketing system must be compatible with the door and frame type.
5. Installation must comply with requirements of NFPA 80.