


StormPro 361 Assembly Anchoring - Single

Head Anchoring Method – Welded Pipe Spacer with 3/8" Powers Lok Bolt AS Jamb Anchoring Method – Welded Pipe Spacer with 3/8" Powers Lok Bolt AS Design Pressure +/- 284 psf







OPENING SIZE	"A" DIMENSION	
UP TO AND INCLUDING 3070	21" MAX. ON CENTER	
OVER 3070 AND UP TO AND INCLUDING 4080	18" MAX. ON CENTER	

Jamb anchor locations may vary provided that the spacing on either side of each jamb anchor does not exceed dimension "A" in table above, distance from bottom corners does not exceed 8", and distance from top corners does not exceed 4". Head anchors shall be provided as shown. Anchors may have up to 1/4" maximum load bearing shim.

Signed and sealed anchor calculations available upon request.

Ceco Door	JOB NO.	PROJECT	SHEET NO.	OF
ASSA ABLOY		LOCATION		
ASSA ABLOY, the global leader in door opening solutions				